

**SUPPLIER DECLARATION OF CONFORMITY (SDoC)****Responsible Supplier Details**

Name:	Haneco Lighting Australia Pty Ltd
Contact Address:	262 Marion Road, Netley, SA 5037 Australia
Telephone:	1300 001 533
Email:	info@haneco.com.au
ABN:	75 601 662 864
Web:	www.haneco.com.au
Responsible Supplier Code:	E2852

Product Details

Product type:	LED Weatherproof Batten	
Product description:	Haneco Dura G2 Weatherproof Batten 4000/4500/5000K	
Trade name:	 (Haneco)	
Item number(s):	DURA06-G2, DURA06-EM-G2	
Electrical rating:	Input Voltage: 220-240Vac	Input Current: 90 mA max.
	Rated Power: 10 / 13 / 15 / 18 W	Power Factor: >0.9
	Insulation Class: Class I	IP Rating: IP65
Item number(s):	DURA12-G2, DURA12-EM-G2	
Electrical rating:	Input Voltage: 220-240Vac	Input Current: 187 mA max.
	Rated Power: 39.5 W	Power Factor: >0.95
	Insulation Class: Class I	IP Rating: IP65

Standard(s) applied:

AS/NZS 60598.1: 2017 Inc A1 + A2
AS/NZS 60598.2.1: 2014 Inc A1 + A2
AS/NZS 60598.2.22: 2019
AS/NZS 2293.3: 2018 Inc A1
AS/NZS 61347.1: 2016 Inc A1 + R1
AS/NZS 61347.2.13: 2018 Inc A1
AS CISPR 15:2017

Report/ Certification Number	Date Issued
Refer Product Compliance Review EPCR-DURA G2	30/07/2025
Conditions	
N/A	

SUPPLIER DECLARATION OF CONFORMITY (SDoC)**Declaration of Conformance**

We Haneco Lighting Australia Pty Ltd declare under our sole responsibility that:

- We are satisfied the product mentioned above is in conformity with the relevant clauses of the above-mentioned standard(s) or other normative document(s) and have determined that it:
 - Complies with the essential safety characteristics and requirements for electrical equipment set out in AS/NZS 3820; and
 - Complies with the requirements of the relevant ACMA Standards made under the Radiocommunications Act 1992 and the Telecommunications Act 1997.
- All product supplied under this declaration will be identical to the product identified above and will not differ in terms of its electrical safety and performance characteristics and material composition.
- Cords, plugs and connectors or other level 3 components permanently attached to the equipment have current certification for Australia and New Zealand. Level 2 components permanently attached to the equipment have a current compliance folder.
- Where this product is sold under a different trade or brand name than that nominated on certification it is the same product cited on the certificate.
- The contents of this form are true and correct.

I am authorised to make this declaration on behalf of the Responsible Supplier.

Name:	Hitesh Solanki
Position:	Category Manager
Date:	30/07/2025
Signature:	