


SUPPLIER DECLARATION OF CONFORMITY (SDoC)

Responsible Supplier Details

Name:	Haneco Lighting Australia Pty Ltd
Contact Address:	262 Marion Road, Netley, SA 5037 Australia
Telephone:	1300 001 533
Email:	info@haneco.com.au
ABN:	75 601 662 864
Web:	www.haneco.com.au
Responsible Supplier Code:	E2852

Product Details

Product type:	LED Emergency Light	
Product description:	Haneco LED Emergency Downlight with Remote Driver	
Trade name:	 HANECO (Haneco)	
Item number(s):	LUME-D40-REMOT, LUME-D40-RE-BK	
Electrical rating:	Input Voltage: 220-240Vac	EM Classification: C0: D40 C90: D40
	Power (Charging): 2.5 W	Power (Standby): 1 W
	Insulation Class: Class II	IP Rating: IP20
Item number(s):	LUME-D63-REMOT, LUME-D63-RE-BK	
Electrical rating:	Input Voltage: 220-240Vac	EM Classification: C0: D63 C90: D63
	Power (Charging): 4.5 W	Power (Standby): 2.5 W
	Insulation Class: Class II	IP Rating: IP20
Standard(s) applied:		
AS/NZS 60598.1:2017		
AS/NZS 61347.1:2016 Inc A1		
AS 61347.2.7: 2019		
AS/NZS 2293.3:2018		
AS CISPR 15:2017		
Report/ Certification Number		Date Issued
Refer Product Compliance Review EPCR-LUME REMOTE		23/09/2025
Conditions		
N/A		

SUPPLIER DECLARATION OF CONFORMITY (SDoC)**Declaration of Conformance**

We Haneco Lighting Australia Pty Ltd declare under our sole responsibility that:

- We are satisfied the product mentioned above is in conformity with the relevant clauses of the above-mentioned standard(s) or other normative document(s) and have determined that it:
 - Complies with the essential safety characteristics and requirements for electrical equipment set out in AS/NZS 3820; and
 - Complies with the requirements of the relevant ACMA Standards made under the Radiocommunications Act 1992 and the Telecommunications Act 1997.
- All product supplied under this declaration will be identical to the product identified above and will not differ in terms of its electrical safety and performance characteristics and material composition.
- Cords, plugs and connectors or other level 3 components permanently attached to the equipment have current certification for Australia and New Zealand. Level 2 components permanently attached to the equipment have a current compliance folder.
- Where this product is sold under a different trade or brand name than that nominated on certification it is the same product cited on the certificate.
- The contents of this form are true and correct.

I am authorised to make this declaration on behalf of the Responsible Supplier.

Name:	Hitesh Solanki
Position:	Category Lead
Date:	23/09/2025
Signature:	