
HANECO LIGHTING LED INSTALLATION GUIDE


VIVA145-TRI


PRODUCT CODE: VIVA145-TRI


Product should be installed by a qualified electrician.


Prior to installation ensure power is off at fuse box to prevent electrical shock.














Clearance Guidelines


Haneco lighting LED down light requires the minimum clearance around heat sink,including thermal insulation and building structural members to be at a minimum of 50mm. This clearance is based on maximum ambient temperature of 70° C.



NON-IC

a recessed luminaire that can be used where normally flammable materials, including building insulation, are or maybe present, but cannot be abutted against any material and cannot be covered in normal use

Dimension	Clearance
A – Clearance above luminaire	150 mm
B – Side clearance to combustible building element	0 mm
C – Side clearance to bulk thermal insulation	50 mm



Fixed guard required where:

- -insulation materials are not secured in position
- -Loose materials are present

